User Window for Displaying Data from the Log Database

()

This chapter describes a window with a new user interface for monitoring functional from version D2000 12.2. If required, the D2000 HI can be started with the original alarm user interface via the command line /OLDUI parameter

- Initial Window Display
- Filter Panel
- Table
- Panel with Detail of the Monitored Event

The **Monitoring** window is used to display information from the log database. It consists of three parts - on the left side there is a hiding panel for filtering monitored system events displayed in a table that forms the central part of the window. In the right part of the window, after double-clicking on the table row, a panel with detailed information about the selected monitored event will be displayed. The filter configuration, as well as the table settings, are automatically saved in the computer's registers when the window for the given user is closed. Therefore, when reopened, this window will open in the state in which it was closed by the user.

ter 5	٩	V Ø L	hľadaný reťazec	Q.	1-26 z 2618	< 1 2 3	101 >	🗉 Detail	$\wedge \lor$
Posledná hodina		Meno	Popis	Čas vzniku udalosti 🗅	Priorita	Príčina udalosti	Užívateľ	Meno:	🏚 SystemError
O residente notante		- SystemD2000	SystemD2000	26. 5. 2020 16:41:43	Informácia	nb1mgre2.HIP	SystemD2000/n	Ponis:	ALARM - System Error
iorita	(5/5)	mb1mgre2.HIP	New Process	26. 5. 2020 16:41:43	Informácia		Disconnect/nb1		no ann ogotern error
		NSYSTEM	System Stop DEMO_S	26. 5. 2020 16:41:49	Informácia			Čas vzniku udalosti:	26. 5. 2020 16:42:18,227
upozomenie		SYSTEM	Start Systemu DEMO	26. 5. 2020 16:42:03	Informácia			Stav alarmu:	Alarm
arm Kritický Alarm		â SystemError	ALARM - System Er	26. 5. 2020 16:42:18	Kritický Alarm	Invalid pasive refe		Stará hodpota:	NoAlarm
nyba		SystemError	ALARM - System Er	26. 5. 2020 16:42:18	Kritický Alarm	Invalid pasive refe		Stara nounota.	NoAlaim
inkt		mb1mgre2.SMC	New Process	26. 5. 2020 16:42:25	Informácia	TCP/IP {127.0.0.1:58	nb1mgre2.SMC/	Nová hodnota:	
jekt		mb1mgre2.HIP	New Process	26. 5. 2020 16:42:36	Informácia	ShM2 (nb1mgre2.Hl	Connect/nb1mg	Priorita:	Kritický Alarm
	R	🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : PROP		1120 - An Po	
		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : DIAG		Ozivatei:	
jekty na schéme		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : CON		Typ udalosti:	Alarm
	_	🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : PROP			Invalid pasivo references in Obio
	🔒 🔒 🔒 🔒	🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : PROP		Príčina udalosti:	ABC
	(10/10)	🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : PROP			
Typ udalosti		🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : TREE			
		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : TREE		Schémy k objektu:	
ogické skupiny		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_B			
		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_B			Autor:
		🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_B			Ćas:
		🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_B			
		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_B		Poznámka:	
		SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO			
		🏚 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICM			
		🏚 SystemWarning	ALARM - System War	26, 5, 2020 16:42:37	Alarm	Missing BMP : ICO			🗉 Uložiť 🕤 Vrátiť zmeny
		SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO_T			
		🋕 SystemWarning	ALARM - System War	26. 5. 2020 16:42:37	Alarm	Missing BMP : ICO			

Initial Window Display

After opening the monitoring window, the data in the table will not be displayed automatically, but it is necessary to press any button with a magnifying glass icon to display the data. The reason for this exception is that reading data from the log database may take longer (log database may be safe, for example), which could unnecessarily slow down the user if the record filter is not set according to his ideals.

Monitorovanie	- D X
∀ Filter 5 Q	Image: Weight and Strategy and Str
> O Posledná hodina V	Meno Popis Čas vzniku udalosti ↑ Priorita Pričina udalosti Užívateľ
 Priorita (5/5) Informácia Upozornenie Alarm Kritický Alarm Chyba 	
✓ Objekt	Monitorovanie
 ✓ Objekty na schéme □ □ □ □ □ □ □ □ □ □ □ □ □ □ □ □ □ □ □	Q Vyhľadať
> Typ udalosti (10/10) > Logické skupiny	
	<

Initial display of the monitoring window

Filter Panel

The filter panel on the left side of the screen is used to define the requirements for displaying information from the log database. There are two buttons in

5 returns the set attributes of the filter to the original state that was when the window was opened. The second button the panel header. The first

calls up the search for records according to the current filter and their display in the table. The orange colour of this button means that the filter has been modified and it is necessary to press the button to display the results in the table. Therefore, filter changes are not automatically reflected in the table, as is the case with other windows, but it is necessary to always press this button after changing the filter (either here in the header of the filter panel or above the table).

At the top of the panel below the header, there is a time interval selector that allows you to define the time depth for displaying data from the log database as follows:

- Last hour monitoring data for the last hour,
 Last 8 hours monitoring data for the last 8 hours,
- · Last 12 hours monitoring data for the last 12 hours,
- Last 24 hours monitoring data for the last day,
 Custom interval user-defined time interval for displaying monitoring data.

∀ Filter	∀ Filter ि ्	∀ Filter 5 Q	∀ Filter	5 9	V Ø	1	hľadaný reťa
> O Posledná hodina V	 Posledná hodina × 26.05.2020 15:55~26.05.2020 16:55 音 	 Posledná hodina Posledná hodina Posledných 8 hodín Posledných 12 hodín Posledných 12 hodín Posledných 24 hodín Ulastný interval 	♥ ♥ Vlastný interval 26.05.2020 15:57:02 « máj 2020 po ut st 27 28 29 30 4 5 6 7	 26.05.2020 16 pi so ne 1 2 3 8 9 10 	Meno → SystemD200 S:57:02 po ut st 1 2 3 8 9 10	0 9 ún 2020 št pi 4 5 11 12	Popis iystemD2000 > >> so ne 6 7 a 13 14
			11 12 13 14 18 19 20 21 25 26 27 28 1 2 3 4 Tento deñ	15 16 17 22 23 24 29 30 31 5 6 7 Tento mesiac	15 16 17 22 23 24 29 30 1 6 7 8	18 19 25 26 2 3 9 10	20 21 27 28 2 4 5 2 11 12 2 2 2 2 2 2 2 2 2 2 2 2 2 2
In front of t After selectin The time selector is followed by	the interval selector, there is a ing the "Custom interval" option a clickable list of priorities	a drop-down button to disp on, it is possible to click in this fie s for monitored events, which a	play a text box with eld and enter the ini are to be to be filter	a detailed t terval that th ed.	ime interval ne user need	ls.	
Enabled priorities look like this:		Alarm			спура		

Disabled (after clicking) loc	ok like this:

The object selector allows you to filter monitoring events either for only one selected object or to enter a filter mask in it.

Upozornenie

Alarm

Kritický Alarm

Chyba

Informácia



When writing in the selection box, objects that contain the entered text are automatically suggested (in the image on the right).

If the user needs to search for an object, it is possible to open a separate selection window with a table by clicking on the icon 🔍 on the right side of the selection box or by double-clicking.

Mask in the object selector



It is possible to write a search mask in the selection box

The mask allows you to include in the list of events only those objects whose names have certain common features. The special characters listed in the following table can be used in the mask.

Character	The Meaning of the character
*	Replaces any number of characters.
?	Replaces one character.
[characters]	Allows you to specify several characters (without a delimiter) that may appear in a specific position.
[^characters]	Allows you to specify several characters (without a delimiter) that cannot appear in a specific position.

If the first character in the mask is an exclamation mark (!), the mask will be evaluated as a Perl compatible regular expression. For example, the expression H..CESA* AND (*.TEPL.* OR *.TEPL_*) can be written as !^H\.CESA.*((\.TEPL.)](\.TEPL_)](_TEPL_)). In monitoring, it is not possible to filter records using a mask with AND and OR operators. However, transcribing into a regular expression can be achieved under certain circumstances.

The scheme selector allows you to filter monitoring events only for objects located on the scheme. The selector works analogously to the object selector, but in this case, it only offers schemes for selection (a filter mask cannot be entered here).

The avant type tree allows	you to filtor recorde b	wayant type. The following	a around of overte are ave	ailabla
			iu uluuus ul eveniis ale ava	allable
	J · · · · · · · · · · · · · ·	J J		

Alarm	All changes of alarm states - origin, vanishing, acknowledgement, etc.
System	Start and stop the system.
Process	All process state changes - start, stop and crash.
Communication	Communication errors.
Operator intervention	Operator interventions in the D2000 HI process.
Event	Event entries.
Login / Logout	Login and logout of the operator in individual processes of the system.
Data export	Export of data from monitored tables.
Spontaneous value change	Spontaneous change of the value of the object type switch, disconnector without operator intervention (circuit breaker tripping).
Time recorder	Special data from communication.



The last part of the filter panel offers event filtering of those objects that are included in the selected logical groups. After clicking in the text box, a popup will appear with a tree of all logical groups. Checking the checkbox on the left for each logical group selects it in the filtered list. The displayed tree is automatically filtered according to the text written in the text field - this way it is easy to search the tree.



The selector with a tree of logical groups and search in this tree.

With the right button on any logical group, it is possible to call up a context menu with the option to collapse or expand the tree to a certain level. Initially, the tree is always fully expanded, but after selecting a specific option to collapse or expand, the last setting is recorded in the window configuration - that is, when the window is opened again, the tree will be expanded according to the last setting from this menu.



Context menu of the logical group tree

Table

(i)

The table shows the monitoring records, in the way that all records are loaded into the table at the beginning. The internal limit is currently about 10 thousand records, if more data was recorded in the selected time interval, the user is informed by a popup with a warning that not all records for the given filter conditions have been read - i.e. only part of the records are displayed. In this case, it is necessary to define more detailed filter conditions in the filter panel to reduce the number of records. The quick search box above the table only searches for records that have already been loaded.

Všeobecné funkcionality tabuky sú popísané v samostatnej kapitole

The general functionalities of the table are described in a separate General table control in the new user interface chapter.

The table contains the foll	owing colum	ns:
-----------------------------	-------------	-----

Column	Column contents
Name	The name of the D2000 system object to which the event relates + a graphic symbol representing the group of monitored events.
Description	Description of the event.
Alarm status (the column is initially hidden in the monitoring window)	Object alarm status after an event (only if the event is of the alarm type)
Event formation time	Formation date and time of the event. If the msec option is checked, the column displays time data to the nearest millisecond.
Priority	Priority indicates the severity of the event. The following five priority levels are implemented in the system (in order from smallest to largest): Information Warning Alarm Critical alarm Error

The equipe of the event	The cause of the monitored event.
The cause of the event	In the case of an event of type *LOG* New value *Logon* - i.e. the user's login contains:
	 the name of the process through which the user logged in - mandatory information, a list of the hardware keys present in case the hardware keys are recognized, the client's IP address if the connection was made through Windows Terminal Services (Remote Desktop) or Citrix MetaFrame.
	For example: NB1.CNF[480,R][917]WTS:172.16.1.134 The user logged in to the NB1.CNF process using Remote Desktop from a workstation with IP=172.16.1.134. An HW key with a unique identifier = 480 was present on the workstation. An HW key with a unique identifier = 917 was present on the server where the process was physically running.
User	The name of the operator logged in at the time of the event (for processes, "Connect" or "Disconnect" is listed in this column).
	 Connect - the process has been connected to the D2000 Server process Disconnect - the process has been disconnected from the D2000 Server process
Old value	The value of the object before the event.
New value	The value of the object after the event.
Event type	Type of monitored event: • ALR - Alarms • SYS - System • PRC - Processes • KOM - Communication • OPR - Operator interventions • EVT - Events • LOG - Login / Logout • DEX - Data export • CHV - Spontaneous value change • TIM - Time recorder
Object Id (hidden column)	HOBJ identifier of the event object
Note (hidden column)	The text of the note entered by the user for the event
Note time (hidden column)	Timestamp of the last modification of the note
Author's notes (hidden column)	Author of the last modification of the note
Columns of attribute logical groups (hidden columns)	Logical groups marked as attributes automatically become columns of this table as well. The names of logical groups that are descendants of this attribute logical group (child in the tree) are displayed in the rows of individual monitored records of those objects that belong to these logical groups.

In the list, you can arrange the data by any column, but by default, it is the **Event Formation Time** column. New values are added for ascending order to the incomplete last page and for descending to the first page of the list

Panel with Detail of the Monitored Event

Double-clicking on any row in the table (list) will open a panel with the event detail. This panel clearly displays all the information from the table about this row. The display is useful for long information in individual columns. The arrows in the header of the panel allow you to move through the rows in the table. The panel always displays information about the currently selected record.

In addition to the displayed information, a list of schemes on which the object (its value) is displayed can be displayed in this detail of the monitored event.

This list of diagrams (see the item Schemes for the object in the picture below) is not loaded immediately, but first, a button will appear in its place, which must be clicked on. The list of schemes is in the form of clickable lines (in case the scheme has the description turned off, it will be displayed and not the name of the scheme). Clicking on a specific scheme will open it in HI.

In addition to the list of schemes, the user is able to enter a note on the monitored event (note item in the image below), which can describe the details of the event in more detail. The username, as well as the time of the last modification, is saved in the database with the text field of the note after pressing the Save button at the end of the panel.

8 Ø 1	Ħ hľadaný∨	Q 1-26 z 159 <	1 2 3 4	5 6	🗉 Detail	$\uparrow \checkmark \times$
Meno	Popis	Stav alarmu	Čas vzniku udalosti ↑	Priorita	Meno:	🏚 P.Alarm
🛶 SystemD2000	SystemD2000		27. 5. 2020 12:03:53	Informá	Popis:	Calculated roof presure
ELF.ALA	Proces spracovania al		27. 5. 2020 12:03:58	Informá	*	
SELF.CLC	Proces vypoctov		27. 5. 2020 12:04:02	Informá	Cas vzniku udalosti:	27. 5. 2020 12:04:14,474
🋕 Archiv1_DBReque	Príliš veľa DB požiada	Normal	27. 5. 2020 12:04:14	Informá	Stav alarmu:	Alarm
SRVAPP02.CLC_R	Proces SELF.CLC na S	Alarm	27. 5. 2020 12:04:14	Alarm	Stará hodnota:	NoAlarm
🌲 SRVARC1_ORA.AI	Varovanie - overit ci n	Normal	27. 5. 2020 12:04:14	Informá	Stara notnota.	NoAlam
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:14	Alarm	Nová hodnota:	On
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:14	Alarm	Priorita:	Alarm
🏦 My_Alarm	High outdoor volta	Alarm	27. 5. 2020 12:04:14	Alarn	11×6. un tra l'a	
🋕 My_Alarm	High outdoor volta	NoKvit	27. 5. 2020 12:04:15	Alarn	Uzivatei:	
🏚 P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:16	Alarn	Typ udalosti:	Alarm
🌲 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:17	Alarn		0.2
🏚 P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:20	Alarn		011
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:21	Alarn	Pricina udalosti:	
🏚 P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:24	Alarn		10
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:25	Alarm		My second simple picture
🋕 My_Alarm	High outdoor volta	NoKvit	27. 5. 2020 12:04:25	Alarn		My simple picture
â My_Alarm	High outdoor volta	Alarm	27. 5. 2020 12:04:26	Alarn	Schémy k objektu:	Pump station
🏚 P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:28	Alarn		S.AxC
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:29	Alarn		
🏚 My_Alarm	High outdoor volta	NoKvit	27. 5. 2020 12:04:30	Alarn		Autor: SystemD2000/nb1mgre2
🏦 My_Alarm	High outdoor volta	Alarm	27. 5. 2020 12:04:31	Alarm		Cas: 27. 5. 2020 12:06:55
🏚 P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:32	Alarm		Alarm vznikol lebo
🏚 P.Alarm	Calculated roof presure	Alarm	27. 5. 2020 12:04:33	Alarn	Poznámka:	
🋕 My_Alarm	High outdoor volta	NoKvit	27. 5. 2020 12:04:35	Alarn		
n P.Alarm	Calculated roof presure	NoKvit	27. 5. 2020 12:04:36	Alarn		Uložiť 🖒 Vrátiť zmeny

Panel with detail of the monitored event