Control the Communication Stations (D2000/Work with D2000 HI/Monitoring and Controlling of D2000 System Objects/Old Control Windows)

Controlling communication stations

!!! OLD CONTROL WINDOWS !!!

Clicking a graphic object with a communication station connected to control (the user has insufficient access rights) opens the following control window.

_	
1	Name of communication station.
2	Description of the communication station.
3	Name of communication protocol.
4	Value of the communication station.
5	Time when the objects has got the current value.
6	Flags (attributes) of the station value. There are displayed only flags, value of which is TRUE.
7	Part of control window intended for station control.

Communication station control

The bottom part of the control window contains buttons to control communication station. They are described in the following table.

Start	Activate the communication with a station in case that the communication is stopped.
Stop	Stop the communication with a station.
Priority	Short-time preferred communication with particular station.
Start Trace	Start a communication trace.
Stop Trace	Stop a communication trace.
Configurati on	Load I/O Tag settings from particular station.
Init	Data initialization from a sub-station archive.
Special	Data recovery from a sub-station archive.
Brow	Insert the controlled object into current page of opened Browser. If Browser is not opened, clicking on this button will open it and the controlled object will be inserted into its first page.
Close	Close the control window.