


Connecting to Control

Connecting graphic objects to control

Connecting to control allows to create a relation of the graphic object to a D2000 system object. Then by means of the graphic object opened in process [D2000 HI](#), you can control, i.e. set a value or other attributes of complex object value.

Connecting of the graphic object to control

1. Select the graphic object, you want to connect to control.
2. In the palette [Connect object](#) - tab **Control** - define the following parameters:
 - Select a D2000 system object or a local variable (button **L**), whose attributes will be controlled by the graphic object.
 - Select one of the mode to control the object: **Set directly**, **Open window**, **Set value**. For the option **Set value** you must enter a value into the input field displayed in the palette. For more information on the control modes see the topic [Modes to control connected object](#).
 - Select the type of reaction - **Button down** (when you press the mouse button above the graphic object in process [D2000 HI](#)) or **Button up** (when you release the mouse button above the graphic object in process [D2000 HI](#)).
 - If required to confirm a change of the object attribute, which is performed in process [D2000 HI](#), check the button **Acknowledge**. If the option **Autoclose** is checked, the control window will be automatically closed after changing any of the object attributes in process [D2000 HI](#).



3. To confirm all defined parameters click the button **T**.

Note 1: Clicking the button **I** sets all the parameters according to the parameters of last connected object.

Note 2: Controlling of [Windows control - Push button](#) is activated only when clicking. It is generated when pushing and releasing the mouse button (i.e. clicking).



Related pages:

[Connecting graphic objects](#)
[Modes to control connected objects](#)