ON CHANGE

ON CHANGE action

Declaration	ON CHANGE objIdent GOTO ProcName [NONE]
Parameters	objtIdent in Value identifier (or a group of values).
	ProcName in Procedure name (it must meet the rules for object name).
Description	The action specifies a procedure (using the name ProcName), that is to be called, if a change of the value <i>objIdent</i> (or some of the group of values) occurs. A value must be derived from the object name (not from local variable). For example correctly: Sec, SV.Structure[2]^Int, incorrectly: _locVar,). A group of values can represent a row, a column or entire object of Structured variable type. <i>For example:</i>
	 the identifier of the second row: SV.Structure[2] (column name is not stated) the identifier of the column Int: SV.Structure[0]^Int (the row index is 0) the identifier of all values (entire structure): SV.Structure, or SV.Structure[0] (the row index is 0).
	The traced value can be identified through HOBJ or VOBJ.
	For example:
	INT _hbj
	ON CHANGE (_hbj) GOTO ValueChanged
	After the action execution, for example:
	ON CHANGE Sec GOTO ValueChanged
	The procedure <i>ValueChanged</i> is to be called always, when a value change of the object <i>Sec</i> occurs (therefore every second). If the following action is performed within the frame of the script:
	ON CHANGE Sec GOTO ValueChanged NONE
	calling the procedure <i>ValueChanged</i> is to be terminated during a value change of the object <i>Sec</i> . At the action notation, it is able to state the structure item:
	ON CHANGE SV.Structure[2]^Int GOTO ValueChanged
	We may respond to a change of one value also in several procedures:
	ON CHANGE Sec GOTO ValueChanged

ON CHANGE Sec GOTO ValueChanged1

In this case, the procedures ValueChanged and ValueChanged1 are to be called during a change of the object Sec.

A procedure called on the basis of a value change must be declared in the following way:

PROCEDURE ProcName(ValueType value, ALIAS _referenceToObject, INT _row, INT _column)

Where:

ProcName is the procedure name, that meets the rules for procedure name.

_value is a parameter, to which a new value of the monitored object (or an item during the monitoring of a structure item change).

ValueType determines the type of the parameter _value. If the type is not selected correctly (in regard to a value changed), an invalid value is to be assigned to the parameter.

_referenceToObject is a parameter of ALIAS type. After the procedure start, it is initialized to refer to the object, which changes the value (in case of monitoring an item, ALIAS is referred to the whole structure, not the item).

_row, _column are the parameters of INT type. They make a difference only if the procedure is called by reasons of a value change of a structured variable item. Otherwise they are set to the value of 0. In case of a value change, the parameter _row contains the serial row number and the parameter _column contains the serial column number within the frame of the particular structured variable.

The action is usable only within the frame of the script of an Active picture or an object of Event type with the active option Server Event.

Example

Example - the script, within the frame of an active picture, that monitors and reports all value changes of: • the object Sec

- the item SV.Structure^Int
- any item in the row Int (SV.Struktura[0]^Int)

to an operator on the desktop of the process D2000 HI.

```
; Handling changes of values
PROCEDURE ValueChanged(REAL _value, ALIAS _obj, INT _row, INT _col)
  ; Is a value of the object Sec changed ?
  IF _obj\HBJ = Sec\HBJ THEN
    MESSAGE "The object Sec changed = " + %IToStr(_value) ON _FROM_HIP
  ; Is a value of the object SV.Structure changed ?
  ELSIF _obj\HBJ = SV.Structure\HBJ THEN
    IF _row = 1 \& _col = 1 THEN
     MESSAGE "The item SV.Structure^Int changed = " + %IToStr(_value)
ON _FROM_HIP
     ELSE
     MESSAGE "In the column SV.Struktura[0]^Int, change of the row = " +
%IToStr(_row) ON _FROM_HIP
    ENDIF
  ENDIF
END ValueChanged
; Initialization part
BEGIN
  ON CHANGE Sec GOTO ValueChanged
  ON CHANGE SV.Struktura^Int GOTO ValueChanged
  ON CHANGE SV.Struktura[0]^Int GOTO ValueChanged
END
```

Related pages:

Script actions