

Configuration Dialog Box (D2000/Alarms - Controlling Exceptions in Logged Process/Display Masks)

Display masks - configuration dialog box

Editing of all objects in the process [D2000 CNF](#) is being performed in the [configuration dialog box](#), a specific part of which is common for all editable objects and another part depends on the type of edited object.

Configuration dialog box of objects of *Display mask* type consists of several tabs containing similar parameters.

[General properties](#)
[Groups](#)
[Masks](#)

General properties

Description

A text string describing the display mask. Maximum: 128 characters.
Possibility to use the [Dictionary](#) (to open press **CTRL+L**).

Mask

Mask

A text string, that will be displayed in the [Alarm list](#) window in process [D2000 HI](#), the **Event description** column.
Maximum: 200 characters.

More information on use of display masks can be found in the chapters describing process alarm configuration of individual object types: [I/O tags](#), [Eval tags](#) and [Switches](#).



Related pages:

[Display masks](#)