

_ERR_NR_TRANS_EX - List of existing errors

The following table contains the list of existing errors returned by the local variable [_ERR_NR_TRANS_EX](#).

Internal name	Value	Description
Error codes during work with system objects		
OK	0	OK.
OBJECT_ALREADY_EXISTS	1	Object already exists.
OBJECT_NOT_FOUND	2	Object does not exist.
INVALID_ACCESS	3	Insufficient access rights.
SHARED_ACCESS_ERROR	4	Access error when trying to edit (object is being edited by other user).
OBJECT_NOT_OPENED	5	Object is not open.
OBJECT_IS_USED	6	Object is used (when trying to delete it).
INVALID_NAME	7	Invalid object name.
FATAL_ERROR	8	Fatal error.
OBJECT_IS_READ_ONLY	9	Object is read-only (when trying to edit or delete it).
OBJECT_HAS_CHILDREN	10	Object has children (when trying to delete it).
SAVE_REFERENCES_ERROR	11	Incorrect object references.
LICENCE_LIMIT_OVERRUN	46	Licence limit overrun (when trying to create a new object).
Error codes for output control		
MANUAL_CTRL_DISABLED	12	Manual control disabled (when trying to set a value manually).
BAD_COMMAND	13	Bad command.
COMMAND_NOT_ACCEPTED	14	Illegal command.
PROCESS_NOT_RUNNING	15	Process for execution of the command is not running.
Error codes for configuration of topology		
CREATE_NEW_ERROR	16	Error during creation of a new object of Topology type.
BAD_PARENT	17	Object has another parent.
NAME_ALREADY_EXISTS	18	Object with given name already exists - it is of other type.
BAD_CONNECT	19	Inappropriate control object for topological node of Terminal type.
Error codes for user's logins		
USER_INVALID_ACCESS	20	Invalid access rights.
LOGON_WRONG_PASSWORD	21	Incorrect password. (version <= 12.2.65)
LOGON_NAME_ERROR	22	Incorrect login name. (version <= 12.2.65)
PASSWORD_EXPIRED	23	Password validity has expired.

USER_IS_DISABLED	24	User login is disabled.
USER_EXPIR_TIME	25	Validity of user's account has expired.
LOGON_NAME_PASS WORD_ERROR	54	Incorrect name or password. (version >= 12.2.67)
Error codes for database backup		
DATABASE_NOT_VAL ID	26	Database not valid.
BACKUP_FAILED	27	Backup failed.
OTHER_ERROR	28	Other error.
PATH_NOT_COMPLE TE	29	Path not complete.
Error codes for access to database (D2000 Archiv, D2000 DBManager, D2000 Server)		
ODBC_ERROR	34	ODBC error.
Error codes for connection to processes		
INVALID_VERSION	30	Incorrect version.
PROCESS_RUN_DISA BLED	31	Cannot start process.
PROCESS_LICENCE_ DISABLED	32	Cannot start process - insufficient licence.
PROCESS_TCPIP_DE NIED	33	Cannot start process - IP address is denied.
Error codes of process D2000 DBManager		
PAGE_ERROR	35	Page error (in case of page access to database).
EDIT_DISABLED	36	Editing disabled (when trying to write to a read-only table).
DBM_SEQUENCE_ER ROR	37	DBManager sequence error (invalid object identifier, non-existing transaction, ...)
DATABASE_OPEN_E RROR	38	Open database error.
BAD_CONDITION	39	Bad conditions.
TOO_MANY_ROWS_I N_SELECT	48	Too many rows in selection (more than specified by the parameter Maximum returned rows in the configuration of object of Database type).
DBM_CONNECTION_ BROKEN_ERROR	49	Connection with database has been interrupted.
DBM_MAX_CONNECT IONS	50	Maximum number of connection to the database has been reached (the parameter Maximum connections in the configuration of object of Database type), new connection has not been created.
STRUCT_CHANGE	51	Change of object of Structure definition type in runtime (rows loaded from database do not correspond to the changed object of Structure definition type and are not to be sent to process D2000 Server).
DBM_DATABASE_OFF	52	Access denied: object of Database type is set to OFF (the parameter Off in the configuration of the object)
Error codes of process D2000 Archiv		
LOAD_TREZOR_ERR OR	40	Error in loading depository database.
CREATE_WRT_FILE_ ERROR	41	Create WRT file error when importing Sybase depository database.
OPEN_TREZOR_ERR OR	42	Error in opening depository database.
CREATE_STATISTICS _ERROR	43	Error in creating statistics file for archive.
Error codes of Tell commands for process D2000 KOM		

DUPLICATE_ADDRESS_ERROR	44	Duplicate address (when changing the address of I/O tag by using the Tell command SETPTADDR)
POINT_NOT_FOUND_ERROR	45	I/O tag not found (for Tell command SETPTADDR).
Error codes of process D2000 Application Manager		
INVALID_DB_PASSWORD	47	Invalid password for access to the configuration database.