ReadPointValue

	unsigned int _stdcall ReadPointValue(struct StationPar * St, struct PointPar * Pt)	
Parameters	St Poin	ter to StationPar structure.
	Pt Pointer to PointPar structure.	
Description Return code	The function ReadPointValue (_ReadPointValue@8 in the <i>Stdcall</i> call convention) is optional and it is called to get the value of defined I/O tag after writing a new value using the function WritePointValue.	
	Code	Description
	RQ_OK	Request executed OK.
	RQ_E RR	An error occurred (the device does not communicate or is out of service, or there is any error), the station changes into the state COM_ERR, or HARD_ERR after returning from the function.
	RQ_IG NORED	The function was ignored and the station status is not changed.

D2000 KomAPI - interface functions