## ReadPointValue

Declaration

unsigned int \_stdcall ReadPointValue(struct StationPar \* St, struct PointPar \* Pt)

**Parameters** 

St Pointer to StationPar structure. Pt | Pointer to PointPar structure.

Description

The function  $\mbox{\bf ReadPointValue}$  (\_ReadPointValue@8 in the  $\mbox{\it Stdcall}$  call convention) is optional and it is called to get the value of defined I/O tag after writing a new value using the function  $\mbox{\it WritePointValue}$ .

Return code

Code	Description
RQ_OK	Request executed OK.
RQ_E RR	An error occurred (the device does not communicate or is out of service, or there is any error), the station changes into the state COM_ERR, or HARD_ERR after returning from the function.
RQ_IG NORED	The function was ignored and the station status is not changed.



## (i) Related pages:

D2000 KomAPI - interface functions