


Insert a New Value into the Archive (Work with D2000 HI)

Insert a new value into archive

In some special cases, you need to manually insert a value into the archive. You must proceed as follows (the procedure can be performed assuming that the dialog box displaying values of the particular archive object is opened on the [D2000 HI](#) desktop - the topic [Browse historical values](#)).

To insert a new value into the archive.

1. Click the the value you want to change in the dialog box displaying values that are read from the archive database.
2. Click the **Insert** button.
3. The dialog box used for settings of a new value is opened.



4. Set required time of the new value and all its attributes - value (**Value** input box), limit state (**Limits** input box), process states (the right list) and value flags (the left list).
5. Click the **OK** button to confirm the performed changes.

Note

- The system will automatically assign the special archive flag USERMODIFY to each value changed this way.