

Configuration of Parameters for the Archive

At its start, the archive reads the necessary parameters from the system registry. Their values are set in the **D2000 Management Console**. Access to the configuration is via the menu **Configuration -> SELF.ARC**.



A list of parameters for the archive is displayed in the window. Parameters can be created, deleted or their values edited.

Vlastnosť	Hodnota
(Default)	
AutoMountPath	
BackupOffset	0:30
BackupPassive	0
BackupPath	D:\D2000\{D2000_V10.0.37_server}\D2000_APP\{App02}\Archiv\SqlBack
BackupPeriode	8
DataTableSlices	0
DeleteInSlice0	1
DeleteInSlices	0

Adding a Parameter

A new parameter can be added after click the button **Create**. The dialog box for defining the parameter opens.

Parameter	Meaning

Key (Kú)	Name of the parameter
Type (Typ)	Type of parameter - STRING or INTEGER.
Value (Hodnota)	Field for entering a value.

Editing Values of a Parameter

The value of any parameter can be changed by clicking on the button  Edit. The dialog box for editing the parameter opens.

Edit static property

Klúč BackupOffset
Typ STRING
Hodnota

Editovať **Zrušiť**