

RdStatusChanged

Declaration

void _stdcall RdStatusChanged(StationPar * St)

Parameters

St	Pointer to StationPar .
----	---

Description

RdStatusChanged (`_RdStatusChanged@4` in *Stdcall* convention) is optional. It is called by the [D2000 KOM](#) when changing the active instance of the [D2000 KOM](#) and when switching the redundancy. The callback procedure [GetRdStateAndInstance](#) is used to detect whether the KOM process is connected to HOT Server and it is an active instance.

Note: Function is called also when using tell command [SET_ACT_INST](#), but the active instance does not change (i.e. process was active and remains still active). So, it is always necessary to determine whether the instance or the D2000 Server was switched on or not by [GetRdStateAndInstance](#).



Related pages:

[D2000 KomAPI - functions](#)